COMMERCIAL RT7 ROOFING
PARAPET HEAD APRON INTERNAL CLADDING

DETAIL NO.	CRT7R008A
DATE DRAWN	28/03/12
FILE REFERENCE	RI-CRT7R008A.DWG



NOTE:
(1) MINIMUM PITCH 3°
(2) FOAM CLOSURE STRIPS ONLY REQUIRED IN HIGH RISK SITUATIONS OF WIND BLOWN MOISTURE ENTERING.

NOTES:

- These details are generally in compliance with the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure are indicative only and are the responsibility of the building designer.
- Thermal break or cavity battens may be required in some circumstances.
- Underlay selection and building wrap types are the responsibility of the designer,
  Alternative support to galvanised netting should be used in severe coastal environments including when aluminium is used.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice www.metalroofer.org.nz & www.roof.co.nz
- Where necessary adjust drawings for purlin battens or cavity battens.
- Details are for steel based materials, other substrate may require some changes.



Bird's beak dimension may vary between manufacturing locations.

©COPYRIGHT DETAIL 2012

A
–
PARAPET DETAIL
1:5