



# COMMERCIAL RIBLINE ROOFING PENETRATION ROUND & WATERSHED TO UNDER RIDGE (Soft Edge)



DETAIL NO. CRRO17B  
 DATE DRAWN 1 0/03/12  
 FILE REFERENCE RI-CRRO17B.DWG

- NOTES:
- (1) SUITABLE FOR PIPES UP TO 500mm DIAMETER.
  - (2) MAX ROOF PITCH FOR THIS FLASHING 45°, MIN PITCH 3°
  - (3) ADDITIONAL SUPPORT FRAMING MAYBE REQUIRED WHEN PENETRATION EXCEEDS 200mm THROUGH ROOF.
  - (4) REFER TO SECTION 6 OF NZMRM CODE OF PRACTICE FOR CATCHMENT AREA LIMITATIONS.

- NOTES:
- These details are generally in compliance with the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by Roofing Industries.
  - The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
  - Details of the supporting structure are indicative only and are the responsibility of the building designer.
  - Thermal break or cavity battens may be required in some circumstances.
  - Underlay selection and building wrap types are the responsibility of the designer, Alternative support to galvanised netting should be used in severe coastal environments, including when aluminum is used.
  - These details are for Roofing Industries profiles as nominated and may not be applicable to other profiles.
  - This drawing is the copyright of Roofing Industries and can only be copied or reproduced with their permission.
  - Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice [www.metaloof.co.nz](http://www.metaloof.co.nz) & [www.roof.co.nz](http://www.roof.co.nz)
  - Where necessary, adjust drawings for purlin battens or cavity battens.
  - Details are for steel based materials, other substrate may require some changes.



©COPYRIGHT DETAIL 2012