

# HTKKBH

EXTRACT SERIES KITCHEN KITS  
THROUGH WALL AND BULKHEAD



**hometech**<sup>TM</sup>  
The Ventilation Specialists



## PRODUCT DESCRIPTION

Rangehood installed with 150dia ducting through mid-floor or bulkhead, up to 1.8m.

## KEY BENEFITS

- Flexible installation: Hometech kits give you more options for the location of your installation.
- Design assistance: Hometech staff are available to advise on design requirements and if required offer a design service suitable for PS1.

## APPLICATIONS

\*This system is suitable for, but not limited to the following areas:

- Kitchen extract through bulkhead, suitable for mid floor applications or rangehoods installed on interior walls in buildings from duplexes and townhouses to apartments.

## PRODUCT COMPLIANCE

- G4: Extract air volume exceeds 50l/s for kitchens
- Healthy Homes: Kitchen Ventilation
- B2, E2

## ELECTRICAL

- Electrical connection excluded.
- All fans to be connected to an isolating switch as per AS/NZS 3000:2018.

## WARRANTY

- 2 year rangehood warranty
- 10 Years for materials and workmanship

Terms and conditions apply.

## SPECIFICATIONS

<b>Air Flow:</b>	> 50 l/s
<b>Diameter:</b>	150dia
<b>Duct Run:</b>	Up to 1.8m
<b>Noise:</b>	58dB (low power)
<b>Install Location:</b>	Kitchen
<b>Minimum Clearance:</b>	Through bulkhead or mid-floor
<b>Rooms Served:</b>	One
<b>Ventilation Type:</b>	Kitchen extract
<b>Filter:</b>	Grease filter
<b>Control:</b>	3 Speed push button
<b>Power:</b>	102W
<b>Add-Ons:</b>	NA

## EXPANSIONS / ALTERNATIVES

- HTKKTW : For back to back installs
- HTKKDU : For longer duct runs
- HTKKTR : For through roof installations
- HTPOBH : When supplying your own range hood
- HTKKBHFW : For fire rated exterior wall applications

## LIMITATIONS

- Minimum of 150mm to fit duct in bulkhead.
- Sufficient replacement air is required for extract efficiency.
- Rangehood fire requirements should be co-ordinated with the fire engineer at design stage.

## INSTALLATION

To be carried out by Hometech to manufacturer's recommendations:

- Duct should be installed in bulkhead before closing in.
- Coordinate any fire requirements early on.
- Rangehoods to be hung after painting and cabinetry install.
- Power point should be supplied by others.

## MAINTENANCE

- Grease filters should be cleaner regularly with warm soapy water or in the dishwasher.
- Rangehood exterior surfaces can be cleaned with a damp cloth.
- If any problems arise, please contact your installation professional.

## CAD DRAWING

Full CAD drawing(s) available upon request

