MASONS Barricade PLUS Window Tape over flashing onto MASONS Barricade Building Wrap extended 20mm each side of opening

14gx75mm Bugle Head Type 17 Screws embedded 10mm max. into panel. Min 50mm from edge.

MASONS AAC render & coating system

50mm AAC ENVIRO Panel

MASONS Barricade PLUS Window Tape

Turn up ends of head flashing 20mm

Approved foam tape adhered to top of window flange

Aluminium Window Head Moulding Flashing with 15° Fall to be installed by builder

MASONS Barricade Building Wrap

45x45 H3.2 AAC ENVIRO Tie

75mm Galv. Screw fixing

Steel Framing

35mm Min Cover

Water resistant air seal

5mm Nominal

Packers

5mm

10mm Min

2mm

Note: MASONS Sill and base shoe flashings must be primed with Plasta Seal and coated with MASONS meshing render

OPENING FLASHING Window Head

Detail 21
Scale 1:2

MASONS Barricade Building Wrap over thermal break

MASONS Barricade PLUS Window Tape over flashing onto MASONS Barricade Building Wrap extended 20mm each side of opening

Turn up ends of head moulding 20mm

BOSTIK Safe Seal flexible sealant

Aluminium Window Head Moulding Flashing with 15° Fall to be installed by builder

Approved foam tape adhered to top of window flange

MASONS Barricade PLUS Window Tape

Packers

Water resistant air seal

Note: Cladding not shown

OPENING FLASHING - Window Head
3D View

MASONS ENVIRO AAC ON 45mm CAVITY STEEL FRAME

Detail 22   NTS