

Vertical track flashing 0.9 mm folded aluminium flashing (hemmed) 150 mm above Meter Box Head.
Alternatively use Dynex Dynaflash

20 x 20 mm metal angle sealed and riveted to meter box

10

Inseal 3259 tape between angle and jamb flashing

Screw through UA 7584 base and fixed to framing with 8g x 2" CSK Sq. S/S self tapping screws.

5

Minimum 5 mm clearance to allow for thermal expansion

Ulltraclad® UA 5833 Soffit Clip Top

Clearance hole in board larger than screw gauge to allow for thermal expansion

Note: Underlay strips to isolate aluminium from treated timber battens
Refer V00

Cavity batten
Refer V00 Batten Options

Ulltraclad® UA 5059 weatherboards (horizontal) fixed with Locator Clips fixed at Max 600 mm horizontal centres with 8g x 2" CSK Sq S/S self tapping screws through batten into stud

Building underlay continuous around opening

Meter box

Flexible flashing tape to sill and jambs

7.5 mm nominal gap

Air seal over PEF Rod around all sides of the meter box

Note: Ensure to alternate spacings of fixings for battens and Locator Clips to avoid risk of splitting batten

