RESIDENTIAL SLIMCLAD WALL CLADDING JAMB FLASHING FOR VERTICAL CLADDING ON CAVITY. (RECESSED WINDOW/DOOR OPTION 1)

Detail Number: RI-RSCW0 | 2B- | Date drawn: 06/09/202 |

Scale: 1:5@ A4

BUILDING WRAP DRESSED INTO AIR SFAI OPENING AS PER E2/AS I ROOFING INDUSTRIES BACK TRAY* FLASHING RUN FROM TOP **PACKERS** OF HEAD FLASHING TO GROUND OR EXIT POINT HORIZONTAL DRAINED BATTEN (7) SILL FLASHING ROOFING INDUSTRIES 'SLIMCLAD' PROFILED METAL CLADDING ALUMINIUM WINDOW 5 mm GAP SCREW FIXING (8) -CONTINUOUS SEAL SEAL & RIVET FLASHING -ROOFING INDUSTRIES JAMB FLASHING

SLIMCLAD IS OUTSIDE THE SCOPE OF E2/AS I BUT MAYBE APPLICABLE FOR NON RESIDENTIAL BUILDINGS OR AS AN ALTERNATIVE SOLUTION

CONTINUOUS COMPRESSIBLE FOAM SEAL -

* Back tray size may require to increase to ensure coverage at ends of head flashing. Turn down end of head flashing

JAMB FLASHING ON CAVITY

GENERAL NOTES:

- These details are to be read with Roofing Industries profile technical summary regarding wind loads and fixings.
- These details are generally in compliance with E2/AS I and/or the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure including cavity batters are indicative only and are the responsibility of the building
 designer. For steel framed buildings thermal break cavity batters may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof \$ Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/A51.
- Details are for steel based materials, other substrates may require some changes.
- All dimensions are nominal.

DETAIL ANNOTATION:

- I. REFER TO E2/AS I FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN DETAILS.
- 3. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- 4. WHERE SUPPORT BRACKETS ARE REQUIRED BY THE WINDOW MANUFACTURER TO CARRY THE FRAME AND GLAZING LOADS THEY MUST BE SUPPLIED AS AN INTEGRAL PART OF THE WINDOW MANUFACTURER'S RECOMMENDATIONS
- 5. LIASE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.
- 6. CAVITY BATTENS CONTAINING CORROSIVE MATERIAL MUST BE SEPARATED FROM METAL CLADDING BY DPC, BUILDING WRAP, PVC OR PAINTING
- CASTELLATED BATTEN, DRAINAGE PLASTIC BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM.
- 8. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- ALTERNATIVELY REFER TO E2/AS I FOR FLASHING COVER GUIDANCE

REFERENCE FLASHINGS: NZ METAL ROOF AND WALL CLADDING CODE OF PRACTICE AND/OR E2/AS I

Copyright detail © 2021

