**EUROSTYLE SPANLOK® VARIABLE PAN(VP)** WALL CLADDING ON PLYWOOD SUBSTRATE SILL FLASHING FOR VERTICAL CLADDING (RECESSED

WINDOW/DOOR OPTION 2) ALUMINIUM WINDOW SUPPORT BAR (refer to window manufacturers recommendations) **PACKERS** FRAME BLOCK 5mm GAP DO NOT SEAL THIS AIR SFAI JUNCTION STOP FND 10 mm min. COVER **BUILDING WRAP DRESSED INTO OPENING AS PER E2/AS1** 50 mm min. SCREW FIXING, TWO 14g T17 SCREWS PENETRATING **ROOFING INDUSTRIES SILL** 45mm INTO THE PRIMARY FLASHING WITH 10° FALL WITH STRUCTURE UNDER FLASHING FIXED TO CL ADDING HORIZONTAL DRAINED **CAVITY BATTEN** WALL UNDERLAY PLYWOOD SUBSTRATE ROOFING INDUSTRIES **EUROSTYLE SPANLOK®** SILL FLASHING ON PLYWOOD Sill flashings stop ended to receive jamb flashings Hem to be clear of pan 2-5mm

## **GENERAL NOTES:**

- These details are to be read with Roofing Industries SPANLOK™ Product Technical Statement and installation guide. These details are generally in compliance with E2/AS1 and/or the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimatley responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure including cavity battens are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1.
- Details are for steel based materials, other substrates may require some changes.
- All dimensions are nominal

Detail Number: RI-ESRWVP-130C

Date drawn: 03/04/2025

Scale: 1:5@ A4

## **DETAIL ANNOTATION:**

- REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN DETAILS.
- ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY. DETAIL MAY BE USED WITH REBATED LINER.
- WHERE SUPPORT BRACKETS REQUIRED BY THE WINDOW MANUFACTURER TO CARRY THE FRAME AND GLAZING LOADS THEY MUST BE SUPPLIED AS AN INTEGRAL PART OF THE WINDOW MANUFACTURER'S RECOMMDENDATIONS.
- LIAISE WITH WINDOW MANUFACTURER PRIOR TO **INSTALLATION**
- SEAL HEAD FLASHING TO WINDOW IN VERY HIGH & EXTRA HIGH WIND ZONES
- 7. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING
- CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM
- FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- ALTERNATIVELY REFER TO E2/AS1 FOR FLASHING COVER 10 **GUIDANCE**
- 11. CLIPS OMITTED FOR CLARITY
- HIGH TO EXTRA HIGH WIND ZONES DOUBLE FIX UNDERFLASHING
- JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS



Apple App Store/Google Play

Copyright detail

