

# EUROSTYLE ROLL SEAM WALL CLADDING WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING

Detail Number: RI-ERSW012B

Date drawn: 02/02/2018

Scale: 1 : 5@ A4

BUILDING WRAP DRESSED INTO  
OPENING WITH 50mm RETURN TO  
INSIDE OF FRAME WITH WINDOW  
FLASHING TAPE INSTALLED OVER  
WRAP TO CORNERS


SEPARATION OF METAL  
CLADDING & TIMBER BATTEN  
CASTELLATED CAVITY  
BATTEN BETWEEN  
VERTICAL BATTENS

ROOFING INDUSTRIES ROLL  
SEAM SECRET CLIP FIXED

ROOFING INDUSTRIES BACK  
TRAY\* FLASHING RUN FROM  
TOP OF HEAD FLASHING TO  
GROUND OR EXIT POINT


GRAB FLASHING RIVET FIXED TO PAN

ROOFING INDUSTRIES JAMB  
FLASHING WITH 10mm FOLD  
BEHIND GRAB FLASHING




## GENERAL NOTES:

1. REFER TO E2/AS 1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
2. A MIN. OF 8mm EFFECTIVE COVER AT SILLS SHALL BE PERMITTED WHERE NECESSARY TO ALLOW FOR TOLERANCES.
3. WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN DETAILS.
4. ARCHITRAVES ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
5. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.
6. ALLOW FOR SEPARATION FROM ANY CORROSIVE TIMBER TREATMENT.
7. ALL DIMENSIONS SHOWN ON DRAWINGS ARE NOMINAL +/- 5mm
8. CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN MAY BE USED WITH THIS SYSTEM.



REFERENCE FLASHINGS:  
NZ METAL ROOF AND WALL  
CLADDING CODE OF PRACTICE.  
E2/AS 1 OR REFER MANUF DETAILING.  
DIMENSIONS ARE INDICATIVE ONLY

- \* Back tray size may require to increase to ensure coverage at ends of head flashings. Back Tray to run from top of head flashing to ground or exit point.
- \* (Dimensions are indicative only)
- \* Turn down end of head flashing



## NOTES:

- These details are generally in compliance the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'. Eurostyle falls outside the criteria of E2/AS 1 and this document is therefore not applicable.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure including cavity battens are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Underlay selection and building wrap types are the responsibility of the designer.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- These details to be read with Roofing Industries profile technical summary regarding wind loads and fixings.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: [www.metalroofing.org.nz](http://www.metalroofing.org.nz) or E2/AS 1.

Copyright detail © 2017

