

DETAIL NO

CMRR004B

DATE DRAWN

16/08/12

FILE REFERENCE

RI-CMRRO04B.DWG


(1) MINIMUM PITCH 3°

(2) FOAM CLOSURE STRIP ONLY REQUIRED IN HIGH RISK SITUATIONS OF WIND BLOWN MOISTURE ENTERING

- These details are generally in compliance with the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by Roofing
- The building designer is ultimately responsible to ensure that details used Details of the supporting structure are indicative only and are the meet the requirements of the NZ Building Code for the specific project
- Underlay selection and building wrap types are the responsibility of the Thermal break or cavity battens may be required in some circumstances responsibility of the building designer
- Alternative support to galvanised netting should be used in severe coastal

These details are for Roofing Industries profile/s as nominated and may not environments including when aluminium is used.

- or reproduced with their permission. This drawing is the copyright of 'Roofing Industries' and can only be copied be applicable to other profiles
- Where necessary adjust drawings for purlin battens or cavity battens Cladding Code of Practice www.metalroofer.org.nz & www.roof.co.nz Further information can be obtained from the NZ Metal Roof & Wall
- Details are for steel based materials, other substrate may require some



may vary between Bird's beak dimension manufacturing locations

©COPYRIGHT DETAIL 2012



