



**CODEMARK™**

**Product description**

DriStud W11 is a fire retardant, fully synthetic, vapour, water barrier and a light diffuser insulation product. It is a laminate of multiple layers with one side white polypropylene non-woven and the other surface metallised film. Metallized film comes in either aluminium finish or anti-glare finish.

**Product purpose or use**

DriStud W11 has a white face to increase light diffusion and reflection. It is used to line walls and under roofs to give a white finish when installed with white facing down or inside.

**Certificate holder**

TCL Hunt Ltd  
7 Fisher Cres, Mt Wellington, Auckland 1064  
PO Box 132-166, Sylvia Park, Auckland, 1644  
www.dristud.co.nz  
Ph +64 9 526 2700

**CodeMark Product Certification Body**

Bureau Veritas Australia Pty Ltd  
3/435 Williamstown Road,  
Port Melbourne VIC, 3207  
Ph: 1800 855 190  
www.bureauveritas.com.au

Sam Guindi  
Product Certification Manager

For and on behalf of  
Bureau Veritas Australia Pty Ltd

# PRODUCT CERTIFICATE

This is to certify that

**DriStud W11**

**Complies with the New Zealand Building Code (NZBC):**

If designed, used, installed and maintained in accordance with the scope of this certificate, the above mentioned product will meet or contribute to meeting the following provisions of the NZBC:

- B1.3.1; B1.3.2; B1.3.3 (a, h); B1.3.4 (b, c, d)
- B2.3.1 (b)
- C3.4 (c)
- F2.3.1
- H1.3.1 (a, b)

Subject to the following conditions and limitations:

1. DriStud W11 shall be installed in accordance with AS/NZS 4200.2-2017 Pliable building membranes and underlays Part 2 Installation.
2. DriStud W11 is required to be covered with the cladding the same day as it is installed.
3. If installed where foil surfaces may be exposed to a corrosive atmosphere (for example agricultural sheds or within 500 metres of the sea), foil surfaces shall face an enclosed, un-vented air space.
4. DriStud W11 shall be supported by safety mesh or other continuous support where available.



**BUREAU  
VERITAS**



WWW.JAS-ANZ.ORG/REGISTER

13 August 2019  
**Date of issue**

CM70040  
**Certificate Number**



**MINISTRY OF BUSINESS,  
INNOVATION & EMPLOYMENT**  
HĪKINA WHAKATUTUKI

- This certificate is issued by an independent certification body accredited by JAS-ANZ, the product certification body appointed by the Chief Executive of the Ministry of Business, Innovation and Employment under the Building Act 2004. The Ministry does not in any way warrant, guarantee, or represent that the building method or product the subject of this certificates conforms with the New Zealand Building Code, nor accept any liability arising out of the use of the building method or product. The Ministry disclaims to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages, and costs arising as a result of the use of the building method(s) or product(s) referred to in this certificate.
- The certificate holder must maintain compliance with the conditions set out in section 15 of the Building (Product Certification) Regulations 2008. This certificate may only be reproduced in its entirety. It is advised to check that this certificate is currently valid and not withdrawn or suspended by referring to the Register of Product Certificates on the Building Performance website <http://www.building.govt.nz>.