

SDoC Identification Number¹: **VYN OUTDOOR XMSW SERIES: 4/10/2024**

Issuer details

Name² (of New Zealand manufacturer or importer):

VYNCO INDUSTRIES (NZ) LTD.

Telephone:

+64 3 379 9283

New Zealand Company No. (if applicable):

CH506239 03/07/91

Email Address:

sales@vynco.co.nz

Contact Address:

388-396 TUAM STREET.
PHILIPSTOWN
CHRISTCHURCH 8149
NEW ZEALAND
www.vynco.co.nz

Medium Risk Article – Details³ (Product name, type, rating, brand, model, batch numbers, and serial numbers, as applicable):

VYNCO OUTDOOR METRO / URBAN SWITCH RANGE – 1G 250V 16A/16AX M80 IP56.

XMSW1S METRO SWITCH 1G SHALLOW, XMSW1SB METRO SWITCH 1G SHALLOW BLACK, XMSW1D 1G DEEP, XMSW1DB 1G DEEP BLACK, XUSW1SWSM URBAN SWITCH 1G SHALLOW SILVER METAL, XUSW1SBBM 1G SHALLOW BLACK METAL, XUSW1DWSM 1G DEEP SILVER METAL, XUSW1DBBM 1G DEEP BLK

The Medium Risk Article listed above, fully complies:

With cited standard(s), as listed⁴:

Standard number and issue year:

AS 3133

Edition / Amendment status:

2020 INC A1

Standard title:

APPROVAL AND TEST SPECIFICATIONS – AIR
BREAK SWITCHES.

AS/NZS ZZ modified

Yes

No ☐

N/A X

Standard number and issue year:

AS/NZS 3100

Edition / Amendment status:

2022 INC A1

Standard title:

APPROVAL AND TEST SPECIFICATIONS –
GENERAL REQUIREMENTS FOR ELECTRICAL
EQUIPMENT.

AS/NZS ZZ modified

Yes

No ☐

N/A X

OR Complies with the Conformity Cooperation Agreement (CCA)⁵

Yes ☐

No ☐

OR is registered on the EECS database & the declarer is registered as the responsible/affiliated supplier⁶ Yes ☐ No ☐ EECS Equipment # _____

Names and addresses of any Evaluating/Testing/Certification organisation or body used

Name(s):

SLG-CPC TEST LABORATORY

Address(es):

NO 11, WU SONG ROAD, DONGCHENG DISTRICT,
DONGGUAN, GUANGDONG PROVINCE CHINA 523117

Name(s):

SAA APPROVALS

Address(es):

UNIT 5, 20 RIVERGATE PLACE MURARRIE
QUEENSLAND 4172 AUSTRALIA

Supporting document(s) used, to show how compliance
with the declared standard(s) is achieved or CCA certification:

Reference to any management quality system involved:
Additional information⁷:

CERTIFICATE OF APPROVAL FOR WALL SWITCH –
16A SINGLE SWITCH XMSW1 & XUSW1 SERIES
TEST REPORT TO AS 3133, AS/NZS 3133 & AS/NZS
3100 FOR VYNCO OUTDOOR SWITCH – 250Vac 16A
IP56 M80

Report Certification or Document
reference N°(s):

SAA-241591-EA

90878-24-70-24-PP002

Issue dates(s):

03/10/2024

02/10/2024

Declaration (signed for and on behalf of):-

Name and position as authorised by the issuer⁸:

SIMON VALE – MANAGING DIRECTOR

Issuer Identification (as affixed to the article):

RCM MARK & SAA-241591-EA
VYNCO METRO OR URBAN XMSW1xxx

Signature:



Date:

04/10/2024