
RESIDENTIAL SLIMCLAD REVERSE RUN WALL CLADDING BALUSTRADE FOR VERTICAL CLADDING ON CAVITY

HORIZONTAL DRAINED H3.2 PACKER TO SLOPE -BATTEN (4) NO FIXING IN TOP OF FLASHING UNDERLAY TO PROVIDE 5° min. slope SEPARATION OF METAL STOPS ENDS TO CLADDING CAPPING AND TIMBER OR COMPRESSIBLE FOAM SEAL KICK-OUT OPTION at bottom edge of vertical flashing CAPPING FLASHING RIVET FIXED TO CLADDING KICK-OUT FLASHING BIRD'S BEAK FLASHING ROOFING INDUSTRIES SCREW FIXING (5) -'SLIMCLAD REVERSE RUN' BUILDING WRAP -PROFILED METAL CLADDING

SLIMCLAD REVERSE RUN IS OUTSIDE THE SCOPE OF E2/AS I BUT MAYBE APPLICABLE FOR NON RESIDENTIAL BUILDINGS OR AS AN ALTERNATIVE SOLUTION

BIRDS BEAK at bottom edge of vertical flashina



NOTES:

- These details are to be read with Roofing Industries profile technical summary regarding wind loads and fixings.
- These details are generally in compliance E2/AS I and/or the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure including cavity battens are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof \$ Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS |.
- Details are for steel based materials, other substrates may require some changes.
- All dimensions are nominal.

Detail Number: RI-RSCWOIIA-I

Date drawn: 25/11/2021

Scale: 1:5@ A4

SITE WIND ZONE	MINIMUM	
(As per NZS3604)	Z (2)	X
SITUATION I (6)	75mm	2 crests
SITUATION 2 \$ 3 (6)	I OOmm	2 crests

DETAIL ANNOTATION:

- I. SITUATION I, 2 \$ 3 AS PER E2/AS I TABLE 7
- EXCLUDES DRIP EDGE.
- 3. CAVITY BATTENS CONTAINING CORROSIVE MATERIAL MUST BE SEPARATED FROM METAL CLADDING BY DPC, BUILDING WRAP, PVC OR PAINTING
- 4. CASTELLATED BATTEN, DRAINAGE PLASTIC
 BATTEN OR APPROVED DRAINED BATTEN
 CAN BE USED WITH THIS SYSTEM
- 5. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- G. ALTERNATIVELY REFER TO E2/AS I FOR FLASHING COVER GUIDANCE

Copyright detail © 2021

