Detail Number: RI-RSCW012C RESIDENTIAL SUMCLAD REVERSE RUN WALL CLADDING Date drawn: 25/11/2021 SILL FLASHING FOR VERTICAL CLADDING. (RECESSED Scale: 1:5@ A4 WINDOW/DOOR) DETAIL ANNOTATION: ALUMINIUM WINDOW PACKERS REFER TO E2/AS I FOR GENERAL WINDOW OPENING FOR 5mm GAP AIR SFAL WRAPPING OF FRAMED OPENING PRIOR TO WINDOW DO NOT SEAL THIS JUNCTION INSTALLATION. WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN 2. 8mm nom. IN DETAILS. I Omm min. COVER 3. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER. 10 50 mm mm. BUILDING WRAP DRESSED INTO WHERE SUPPORT BRACKETS ARE REQUIRED BY THE WINDOW 4 OPENING AS PER E2/AS I MANUFACTURER TO CARRY THE FRAME AND GLAZING LOADS - STOP END THEY MUST BE SUPPLIED AS AN INTEGRAL PART OF THE

OPTIONAL CONTINUOUS

ROOFING INDUSTRIES

ROOFING INDUSTRIES

REFERENCE FLASHINGS:

NZ METAL ROOF AND WALL

'SLIMCLAD REVERSE RUN'

PROFILED METAL CLADDING

COMPRESSIBLE FOAM SEAL

SILL FLASHING WITH 10° FALL

- WINDOW MANUFACTURER'S RECOMMENDATIONS.
- 5. LIASE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.
- FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED 6. AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- 7. ALTERNATIVELY REFER TO E2/AS1 FOR FLASHING COVER GUIDANCE

SLIMCLAD REVERSE RUN IS OUTSIDE THE SCOPE OF E2/AS | BUT MAYBE APPLICABLE FOR NON RESIDENTIAL CLADDING CODE OF PRACTICE BUILDINGS OR AS AN ALTERNATIVE SOLUTION DIMENSIONS ARE INDICATIVE ONLY

NOTES:

SCREW FIXING (6) -

- ٠ These details are to be read with Roofing Industries profile technical summary regarding wind loads and fixings.
- . These details are generally in compliance E2/AS I and/or the NZ Metal Roof & Wall Cladding Code of Practice and in some cases specific details by 'Roofing Industries'.
- The building designer is ultimately responsible to ensure that details used meet the requirements of the NZ Building Code for the . specific project.
- . Details of the supporting structure including cavity battens are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's . recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles. .
- ٠ This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1.
- . Details are for steel based materials, other substrates may require some changes.
- All dimensions are nominal

SILL FLASHING

Sill flashings stop ended to receive jamb flashings.

