

Sponsors		Certificate number	Certificate issue date	Certificate expiry date
Austaron Pty Ltd 17-30 Heathcote Road Moorebank Australia	Lotte Chemical 14F-16F Lotte World Tower 300 Olympic-ro Songpa-gu Seoul South Korea	FAS200112 SFC1.1	19 May 2020	30 April 2025

Description of assessed product

The referenced report documents the findings of the assessment undertaken to determine the likely fire hazard properties of Staron Solid Surface and Mario Romano Wall panels if tested in accordance with AS ISO 9705:2003 (R2016) and classified in accordance with AS 5637.1:2015.

Assessed product performance

The element of construction described above was assessed by this laboratory on behalf of the test sponsor in accordance with the stated test standard in Table 1 and achieved the results outlined in Table 2. Complete description of the assessed construction can be found within the referenced assessment report(s) or regulatory information report(s).

Table 1 Test standard and assessment report details

Referenced report	Test standard	Referenced report issue date	Referenced report expiry date
FAS200112 R1.1	AS ISO 9705:2003 and AS 5637.1:2015	19 May 2020	30 April 2025

Table 2 Formal assessment summary

Product	Group number AS 5637.1	SMOGR _{ARC}	Group number C/VM2 – Verification Method	Average smoke production rate
Staron Solid Surface	1	< 100 m ² /s ²	1-S	< 5.0 m ² /s
Mario Romano Walls	1	< 100 m ² /s ²	1-S	< 5.0 m ² /s

Conditions/validity

- This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance.
- The RIR (regulatory information report) or the main assessment report must be provided for regulatory requirements and evidence of compliance.
- Reference should be made to the relevant assessment report or regulatory information report to determine the applicability of the test result to a proposed installation. Full details of the constructions and justification for the conclusions given, along with the validity statements, are given in the assessment reports.
- The results of the assessment report may be used to assess fire hazard, but it should be recognised that a single test method will not provide a full assessment of fire hazard under all conditions.
- All work and services carried out by Warringtonfire Australia are subject to and conducted in accordance with our standard terms and conditions. These are available on request or at <https://www.element.com/terms/terms-and-conditions>.

Testing authority	Warringtonfire Australia Pty Ltd	
Address	Unit 2, 409-411 Hammond Road, Dandenong South, VIC 3175	
Phone	T: +61 (0)3 9767 1000	
ABN	81 050 241 524	
Email	info.fire.melbourne@warringtonfire.com	
Authorisation	Prepared by:	Reviewed by:
		
	Yomal Dias	Omar Saad