EUROSTYLE® PANELOK® SHEET LIST

Detail Number: RI-ESPWVC-000A

Date drawn: 25/02/2025

Scale: @ A4

Residential Interlocking Cladding and Soffit Sheet List		
Sheet Number	Туре	Sheet Name
EUROSTYLE® PANELOK®		
RI-ESPWVC-000A	EUROSTYLE® PANELOK®	SHEET LIST
RI-ESPWVC-000B	EUROSTYLE® PANELOK®	PROFILES & ACCESSORIES
RI-ESPWVC-000C	EUROSTYLE® PANELOK®	PROFILE SUMMARY - INTERLOCKING CLADDING AND SOFFIT
RI-ESPWVC-010	EUROSTYLE® PANELOK® CLADDING	SOFFIT FLASHING FOR VERTICAL CLADDING ON CAVITY
RI-ESPWVC-010A	EUROSTYLE® PANELOK® CLADDING	BARGE CAP DETAIL FOR VERTICAL CLADDING ON CAVITY
RI-ESPWVC-030A	EUROSTYLE® PANELOK® CLADDING	WALL CLADDING EXTERNAL VERTICAL CORNER ON CAVITY
RI-ESPWVC-040A	EUROSTYLE® PANELOK® CLADDING	WALL CLADDING INTERNAL VERTICAL CORNER ON CAVITY
RI-ESPWVC-050	EUROSTYLE® PANELOK® CLADDING	WALL CLADDING BASE OF VERTICAL CLADDING ON CAVITY
RI-ESPWVC-130A	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR HEAD FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE
RI-ESPWVC-130B	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE OPTION 1
RI-ESPWVC-130B-1	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE OPTION 2
RI-ESPWVC-130C	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR SILL FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE
RI-ESPWVC-140A	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR HEAD FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CLADDING LINE
RI-ESPWVC-140B	EUROSTYLE® PANELOK® CLADDING	WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING - WINDOW ON CLADDING LINE
RI-ESPWVC-140C	EUROSTYLE® PANELOK® CLADDING	SILL FLASHING FOR VERTICAL CLADDING ON CAVITY (WINDOW/DOOR ON CLADDING LINE)
RI-ESPWVC-160	EUROSTYLE® PANELOK® CLADDING	WALL PIPE PENETRATION
RI-ESPWVC-170	EUROSTYLE® PANELOK® CLADDING	TRANSVERSE JUNCTION FOR VERTICAL CLADDING ON CAVITY
RI-ESPWVC-180	EUROSTYLE® PANELOK® CLADDING	SHEET PACKER OPTIONS







- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Roofing Industries roof.co.nz

EUROSTYLE® PANELOK® CLADDING SOFFIT FLASHING FOR VERTICAL CLADDING ON CAVITY



Detail Number: RI-ESPWVC-010

Date drawn: 25/02/2025

Scale: 1:5@ A4

DETAIL ANNOTATION:

- 1. HIGH TO EXTRA HIGH WIND ZONE DOUBLE FIX UNDERFLASHINGS.
- 2. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 3. CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 6. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



Detail Number: RI-ESPWVC-010A EUROSTYLE® PANELOK® CLADDING BARGE CAP DETAIL FOR VERTICAL CLADDING ON CAVITY



DETAIL ANNOTATION:

- HIGH TO EXTRA HIGH WIND ZONE DOUBLE FIX UNDERFLASHINGS. 1.
- TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS 2. MUST BE SEPARATED FROM METAL CLADDING.
- 3 CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM.
- FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL 4. STATEMENT AND INSTALLATION GUIDE.
- 5. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.

AIR FLOW

FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE 6. SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED

0 min

Copyright detail © 2025

Date drawn: 25/02/2025



- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building • designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay . manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission. •
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



Detail Number: RI-ESPWVC-030A EUROSTYLE® PANELOK® CLADDING WALL CLADDING EXTERNAL VERTICAL CORNER ON CAVITY



DETAIL ANNOTATION:

- TREATED TIMBER CAVITY BATTENS CONTAINING 1 CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- CASTELLATED BATTEN OR APPROVED DRAINED BATTEN 2. CAN BE USED WITH THIS SYSTEM.
- FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING 3. FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 4 FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- . The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building • designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay . manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles. .
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission. •
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Copyright detail © 2025

Date drawn: 25/02/2025





GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.





GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR HEAD FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE



Detail Number: RI-ESPWVC-130A Date drawn: 25/02/2025

Scale: 1:5@ A4

DETAIL ANNOTATION:

- 1. REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- 2. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- 3. JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. SEAL HEAD FLASHING TO WINDOW IN VERY HIGH & EXTRA HIGH WIND ZONES.
- 6. CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN MAY BE USED WITH THIS SYSTEM.
- 7. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 8. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 9. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- 10. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.

HEAD FLASHING



Copyright detail © 2025





GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
 Europeration can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metal.com
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Detail Number: RI-ESPWVC-130B EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE OPTION 1



DETAIL ANNOTATION:

- REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR 1. WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION
- 2. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE 3 ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- ALLOW FOR SEPARATION FROM ANY CORROSIVE TIMBER 5 TREATMENTS.
- CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN 6. MAY BE USED WITH THIS SYSTEM
- 7 TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 8. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 9 FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION. 10.



* Back trav size may require to increase to ensure coverage at ends of head flashings. Back Tray to run from top of head flashing to ground or exit point.

- * (Dimensions are indicative only)
- * Turn down end of head flashing

Copyright detail © 2025

Date drawn: 25/02/2025

Scale: 1:5@ A4



GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building • designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay . manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles. .
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission. •
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Detail Number: RI-ESPWVC-130B-1 EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE OPTION 2



DETAIL ANNOTATION:

- 1. REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- 2 ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE 3. ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- FOR FIXING METHODS REFER TO PANELOK PRODUCT 4. TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5 ALLOW FOR SEPARATION FROM ANY CORROSIVE TIMBER TREATMENTS.
- CASTELLATED TIMBER BATTEN OR APPROVED DRAINED 6. BATTEN MAY BE USED WITH THIS SYSTEM.
- 7 TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY. 8.
- FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED 9 AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH I OCATED
- LIAISE WITH WINDOW MANUFACTURER PRIOR TO 10. INSTALLATION.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building • designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay . manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission. •
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Copyright detail © 2025

Date drawn: 25/02/2025



Detail Number: RI-ESPWVC-130C EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR SILL FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CAVITY LINE



DETAIL ANNOTATION:

- REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING 1 OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN 2. DETAILS.
- 3. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY. DETAIL MAY BE USED WITH REBATED LINER.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. 5. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- 6 SEAL HEAD FLASHING TO WINDOW IN VERY HIGH & EXTRA HIGH WIND ZONES
- 7. CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN MAY BE USED WITH THIS SYSTEM.
- 8 TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 9. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 10. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 11. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building • designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay . manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles. .
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission. •
- . Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metalroofing.org.nz or E2/AS1 where applicable.
- . Details are for steel-based materials, other substrates may require some changes.
- . All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Copyright detail © 2025

Date drawn: 25/02/2025



EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR HEAD FLASHING FOR VERTICAL CLADDING ON CAVITY - WINDOW ON CLADDING LINE

Detail Number: RI-ESPWVC-140A Date drawn: 25/02/2025

Scale: 1:5@ A4



DETAIL ANNOTATION:

- 1. REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- 2. WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN DETAILS.
- 3. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- 6. SEAL HEAD FLASHING TO WINDOW IN VERY HIGH & EXTRA HIGH WIND ZONES.
- 7. CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN MAY BE USED WITH THIS SYSTEM.
- 8. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 9. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 10. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 11. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

HEAD FLASHING



EUROSTYLE® PANELOK® CLADDING WINDOW / DOOR JAMB FLASHING FOR VERTICAL CLADDING - WINDOW ON CLADDING LINE

Detail Number: RI-ESPWVC-140B Date drawn: 25/02/2025

Scale: 1:5@ A4



DETAIL ANNOTATION:

- 1. REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- 2. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- 3. JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. ALLOW FOR SEPARATION FROM ANY CORROSIVE TIMBER TREATMENTS.
- 6. CASTELLATED TIMBER BATTEN OR APPROVED DRAINED BATTEN MAY BE USED WITH THIS SYSTEM.
- 7. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 8. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 10. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
 Eurther information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metal.com
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



EUROSTYLE® PANELOK® CLADDING SILL FLASHING FOR VERTICAL CLADDING ON CAVITY (WINDOW/DOOR ON CLADDING LINE)



DETAIL ANNOTATION:

- 1. REFER TO E2/AS1 FOR GENERAL WINDOW OPENING FOR WRAPPING OF FRAMED OPENING PRIOR TO WINDOW INSTALLATION.
- 2. WINDOW PROFILE TO BE SELECTED TO ACHIEVE COVER SHOWN IN DETAILS.
- 3. ARCHITRAVE'S ARE SHOWN FOR CONSISTENCY ONLY, DETAIL MAY BE USED WITH REBATED LINER.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. WHERE SUPPORT BRACKETS ARE REQUIRED BY THE WINDOW MANUFACTURER TO CARRY THE FRAME AND GLAZING LOADS THEY MUST BE SUPPLIED AS AN INTEGRAL PART OF THE WINDOW MANUFACTURER'S RECOMMENDATIONS.
- 6. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 7. CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM
- 8. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED
- 9. JOINERY AND JOINERY FLASHING INTERFACE IS INDICATIVE ONLY. REFER TO SELECTED JOINERY MANUFACTURER'S RECOMMENDATIONS AND DETAILS.
- 10. LIAISE WITH WINDOW MANUFACTURER PRIOR TO INSTALLATION.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

Copyright detail © 2025



Scale: 1 : 5@ A4

Date drawn: 25/02/2025

Detail Number: RI-ESPWVC-140C

EUROSTYLE® PANELOK® CLADDING WALL PIPE PENETRATION

Detail Number: RI-ESPWVC-160 Date drawn: 25/02/2025

Scale: 1:5@ A4



DETAIL ANNOTATION:

- 1. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE MATERIAL MUST BE SEPARATED FROM METAL CLADDING.
- 2. CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM
- 3. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



EUROSTYLE® PANELOK® CLADDING TRANSVERSE JUNCTION FOR VERTICAL CLADDING ON CAVITY

Detail Number: RI-ESPWVC-170

Date drawn: 25/02/2025

Scale: 1:5@ A4



DETAIL ANNOTATION:

- 1. TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE TREATMENTS MUST BE SEPARATED FROM METAL CLADDING.
- 2. CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM.
- 3. CLOSE OFF ANY ROOF VENTILATION TO WALL CAVITY.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED

INTER-STOREY FLASHING

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay
 manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.



EUROSTYLE® PANELOK® CLADDING SHEET PACKER OPTIONS

Detail Number: RI-ESPWVC-180 Date drawn: 25/02/2025

Scale: 1:5@ A4



DETAIL ANNOTATION:

1

- TREATED TIMBER CAVITY BATTENS CONTAINING CORROSIVE MATERIAL MUST BE SEPARATED FROM METAL CLADDING.
- CASTELLATED BATTEN OR APPROVED DRAINED BATTEN CAN BE USED WITH THIS SYSTEM
 FASTENERS TO BE COMPATIBLE WITH
 - FASTENERS TO BE COMPATIBLE WITH MATERIAL BEING FIXED AND THE SUITABLE GRADE FOR THE ENVIRONMENT IN WHICH LOCATED.
- 4. FOR FIXING METHODS REFER TO PANELOK PRODUCT TECHNICAL STATEMENT AND INSTALLATION GUIDE.
- 5. PACKERS REQUIRED FOR PANEL WIDTHS OF 256mm AND GREATER.

GENERAL NOTES:

- These details to be read with Roofing Industries Eurostyle® panelok® Product Technical Statement and Installation Guide.
- The building designer is ultimately responsible to ensure that the details used meet the requirements of the NZ Building Code for the specific project.
- Details of the supporting structure (including cavity battens if used) are indicative only and are the responsibility of the building designer. For steel framed buildings thermal break cavity battens may be required.
- Roof/wall underlay selection are the responsibility of the designer. Underlay to be installed in accordance with underlay manufacturer's recommendations and requirements.
- These details are for Roofing Industries profile/s as nominated and may not be applicable to other profiles.
- This drawing is the copyright of 'Roofing Industries' and can only be copied or reproduced with their permission.
 Eurther information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: www.metal.com
- Further information can be obtained from the NZ Metal Roof & Wall Cladding Code of Practice: <u>www.metalroofing.org.nz</u> or E2/AS1 where applicable.
- Details are for steel-based materials, other substrates may require some changes.
- All dimensions are nominal.
- Fixing: The designer needs to check the screw manufacturers technical data of the selected screw type for the design wind load and the material being fastened to.

