

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-18-03-05-01

Products: Classen-laminate floor coverings with following structures:
[7] Reclaimed Oak, [8] Pemberton Oak, [11] Algonkin Hickory,
[26] Sierra Oak, [36] Hard Rock, [45] Piano Hochglanz

Client: Classen Industries GmbH, An der Birkenpfehlheide 6, 15837 Baruth

Order: Determination of the slippery resistance
according to EN 13893:2003 / Classification according to EN 14041:2008

Test report: 2718097

Test result:


Structure	Property	Determined value	Declaration according to EN 14041:2008
[7] Reclaimed Oak	Anti-sliding properties according to EN 13893:2003	$\mu = 0.51$	DS
[8] Pemberton Oak		$\mu = 0.56$	DS
[11] Algonkin Hickory		$\mu = 0.45$	DS
[26] Sierra Oak		$\mu = 0.44$	DS
[36] Hard Rock		$\mu = 0.55$	DS
[45] Piano Hochglanz		$\mu = 0.41$	DS

μ ... Coefficient of friction

Dresden, 05 March 2018



Head of laboratory

Engineer in charge