



BRANZ Appraised

Appraisal No. 628 [2014]

POLYGOLD PURE INSULATION

Appraisal No. 628 [2014]

This Appraisal replaces BRANZ Appraisal No. 628 [2008].

Amended 20 November 2015



BRANZ Appraisals

Technical Assessments of products for building and construction.



Alsynite NZ Limited

PO Box 10 409
Te Rapa
Hamilton

Tel: 07 850 5088

Fax: 07 850 5003

Freephone: 0800 257 964

Web: www.alsynite.co.nz



BRANZ

BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

- 1.1 Polygold Pure Insulation is a resin bonded fibrous glasswool thermal insulating material for use in framed walls, ceilings and roofs of buildings.

Scope

- 2.1 Polygold Pure Insulation has been appraised as a thermal insulation material for framed or part-framed walls, ceilings and roofs of domestic and commercial buildings.

Building Regulations

New Zealand Building Code (NZBC)

- 3.1 **In the opinion of BRANZ, Polygold Pure Insulation if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:**

Clause B2 DURABILITY: Performance B2.3.1 [a] not less than 50 years, B2.3.1 [b] 15 years. Polygold Pure Insulation will meet these requirements. See Paragraph 8.1.

Clause E3 INTERNAL MOISTURE: Performance E3.3.1. Polygold Pure Insulation will contribute to meeting this requirement. See Paragraphs 13.1 and 13.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Polygold Pure Insulation meets this requirement and will not present a health hazard to people.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1 [a] and H1.3.2 E. Polygold Pure Insulation will contribute to meeting these requirements. See Paragraphs 14.1 and 14.2.

- 3.2 This is an Appraisal of an Acceptable Solution in terms of New Zealand Building Code Compliance. Polygold Pure Insulation thermal resistance [R-value] has been determined by testing to AS/NZS 4859.1 which is an acceptable method.

Technical Specification

4.1 Polygold Pure Insulation is a resin bonded fibrous glasswool insulation manufactured of recycled and/or virgin glass and polyester binder. Polygold Pure Insulation is available as set out in Table 1.

Table 1: Polygold Pure Insulation product table

R-value	Nominal Thickness [mm]	Width [mm]	Length [mm]	Nett Area [m ²]	Density [kg/m ³]
Polygold Pure Wall Biscuit					
2.2	90	580	1140	10.5	12.0
2.6	90	580	1140	5.2	24.0
Polygold Pure Ceiling Biscuit					
3.2	140	432	1220	6.3	10.5
3.6	160	432	1220	6.3	10.0
4.0	180	432	1220	5.7	9.3
4.6	190	432	1220	4.2	12.0
Polygold Pure Blanket					
2.3	100	1200	10000	12.0	12.0
2.8	110	1200	7000	8.4	14.0
3.6	140	1200	5000	6.0	16.0

4.2 Polygold Pure Insulation is yellow/brown in colour and is compression packaged in yellow pre-printed polythene bags. Each package is supplied with attached labelling in compliance with AS/NZS 4859.1.

4.3 Accessories used with Polygold Pure Insulation, which are supplied by the insulation installer, are wire netting, plastic strapping and fixings.

Handling and Storage

5.1 Polygold Pure Insulation must be stored under cover and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.

5.2 In general, insulation products are sensitive to the length of time they are stored in compression packaging. Product that does not recover to its nominal thickness may not achieve the stated R-value.

Technical Literature

6.1 Refer to the Appraisals listing on the BRANZ website for details of the current Technical Literature for Polygold Pure Insulation. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

7.1 Polygold Pure Insulation is intended for use as thermal insulation to meet the requirements of the NZBC. Polygold Pure Insulation can be used to meet the minimum schedule method R-values of NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Greater construction R-values can be achieved where specific design is used. For construction R-values refer to BRANZ House Insulation Guide. Product R-values and dimensions are given in Table 1.

- 7.2 Polygold Pure Insulation is designed to be friction-fitted between wall, ceiling or roof framing. It can also be laid directly over ceiling lining, over ceiling battens or joists/truss chords. In other horizontal situations, it must be adequately supported by wire netting or some other suitable durable material.
- 7.3 The insulation thickness should be selected to suit the framing cavity. In walls the insulation should be a snug fit between the lining and the underlay. The Polygold Pure Wall Biscuit is for 90 mm wall cavities. Polygold Pure Insulation must not be compressed into cavities less than the insulation's nominal thickness.
- 7.4 When the insulation is installed in walls with a drained cavity and the stud spacings are greater than 450 mm, an intermediate means of restraining the insulation from bulging into the cavity must be installed in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.5.
- 7.5 To prevent moisture transfer and to provide roof ventilation, a separation of 25 mm minimum is required between the insulation and any rigid substrate or flexible roof underlay.
- 7.6 The building envelope must be constructed to ensure the insulation remains dry during installation and throughout the life of the building.
- 7.7 The clearance requirements for heating appliances and downlights must be met and reference made to the manufacturers instructions and NZS 4246. See Paragraph 10.1 - 10.3.

Durability

Serviceable Life

- 8.1 Where the building is maintained so that provisions of the NZBC E2 and E3 Clauses are met, and where the insulation is not crushed or exposed to conditions that will diminish its thermal performance [e.g. moisture], then it can expect to have a serviceable life of at least 50 years.

Maintenance

- 9.1 Insulation that has become damp must be removed and the cause of dampness repaired. Cavities must be clean and dry before fitting new insulation of an equivalent thermal rating. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.

Prevention of Fire Occurring

- 10.1 Separation or protection must be provided to Polygold Pure Insulation from heat sources such as fire places, heating appliances, flues, chimneys and downlights. Refer to Part 7 of NZBC Acceptable Solutions C/AS1 to C/AS6 and NZBC Verification Method C/VM1.

Downlights

- 10.2 Recessed luminaries shall be of type and be installed in accordance with NZBC Acceptable Solution C/AS1 to C/AS6, Section 7.4.
- 10.3 Insulation materials must maintain a clearance of 100 mm to undefined recessed luminaries in existing buildings.

Control of Internal Fire and Smoke Spread

- 11.1 The completed wall and ceiling system, including the surface lining product enclosing the Polygold Pure Insulation from the adjacent occupied space, must achieve the Group Number for internal surface finish requirements as specified in the relevant NZBC Acceptable Solutions C/AS1 to C/AS6.

External Moisture

- 12.1 The total building envelope must be weathertight and comply with the requirements of NZBC Clause E2 to ensure that the insulation remains dry in use.
- 12.2 The moisture content of the construction materials at the time of installing and enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 10.2 (a), or a lower moisture content if required by the lining manufacture.

Internal Moisture

- 13.1 Buildings must provide an adequate combination of thermal resistance, ventilation and space temperature to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate. This does not apply to Communal Non-residential, Commercial, Industrial, Outbuildings or Ancillary buildings.
- 13.2 Roofs and walls of housing complying with the Schedule Method for Compliance with Clause H1.3.2 E will have adequate thermal resistance. Other buildings may require more thermal insulation to satisfy the requirements of NZBC Acceptable Solution E3/AS1 than that to satisfy the energy efficiency provisions alone.

Energy Efficiency

- 14.1 Polygold Pure Insulation will contribute to meeting the requirements of NZBC Clause H1 Performance H1.3.1 (a) and H1.3.2 E by compliance with NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Refer to Paragraphs 7.1 - 7.7.
- 14.2 Polygold Pure Insulation R-values have been determined by BRANZ testing to AS/NZS 4859.1 and are given in Table 1.

Installation Information

Installation Skill Level Requirements

- 15.1 Installation of Polygold Pure Insulation must be completed by an installer with an understanding of insulation installation.

General

- 16.1 Installation of Polygold Pure Insulation must be in accordance with the Technical Literature and this Appraisal. NZS 4246 should be used as a guide for installing insulation in residential buildings.
- 16.2 The product must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less.
- 16.3 Polygold Pure Insulation must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.
- 16.4 Polygold Pure Insulation is supplied in biscuit and blanket form [see Table 1]. The product is able to be cut to suit wall cavities and when fitted between roof or ceiling framing. The insulation must be neatly friction-fitted between framing members so that the potential for gaps and convective heat loss is reduced. In wall cavities, the insulation must be neatly friction-fitted between framing members to prevent sagging. In ceiling or roofs, the insulation may be fitted between framing members or fitted over framing members and butted tightly. The insulation must extend to the external wall top plates. The insulation must not be folded, tucked or compressed. A close, even fit provides the most efficient thermal performance. Wherever possible the insulation should be fitted beneath wiring or plumbing.
- 16.5 The clearance requirements for heating appliances and downlights must be followed.

Inspections

- 16.6 The Technical Literature, this Appraisal and NZS 4246 must be referred to during the inspection of Polygold Pure Insulation installations.

Health and Safety

- 17.1 Refer to the Technical Literature and NZS 4246 for guidance on health and safety requirements such as personal protective clothing and installation hazard assessment.

Basis of Appraisal

The following is a summary of the technical investigations carried out:

Tests

- 18.1 BRANZ has carried out thermal resistance testing of Polygold Pure Insulation in accordance with AS/NZS 4859.1.

Other Investigations

- 19.1 An assessment of the durability of Polygold Pure Insulation has been made by BRANZ technical experts.
- 19.2 The manufacturer's Technical Literature including Installation Instructions have been reviewed by BRANZ and found to be satisfactory.
- 19.3 Site inspections have been undertaken by BRANZ to assess the practicability of installation.

Quality

- 20.1 The manufacture of Polygold Pure Insulation has been examined by BRANZ, including methods adopted for quality control. Details of the manufacturing processes, and quality and composition of the raw materials used were obtained and found to be satisfactory.
- 20.2 Alsynite NZ Limited is responsible for the quality of the product supplied.
- 20.3 Quality of installation of the product on site is the responsibility of the installer.
- 20.4 Quality of maintenance of the building to ensure the insulation material remains dry is the responsibility of the building owner.

Sources of Information

- AS/NZS 4859.1: 2002 Materials for the thermal insulation of buildings.
- BRANZ House Insulation Guide, Fifth Edition 2014.
- NZS 4246: 2006 Energy efficiency - Installing insulation in residential buildings.
- Compliance Document for New Zealand Building Code Energy Efficiency Clause H1, Department of Building and Housing, Third Edition, October 2007 [including Amendment 2, October 2011].
- Ministry of Business, Innovation and Employment Record of Amendments for Compliance Documents and Handbooks.
- The New Zealand Building Regulations 1992.

Amendments

Amendment No. 1, dated 20 November 2015.

This Appraisal has been amended to update the Appraisal Holder's contact details, update fire clauses as per NZBC Fire Clauses C1 to C6 Protection from Fire and A3 Building Importance Levels, and to clarify Health and Safety requirements.



In the opinion of BRANZ, **Polygold Pure Insulation** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Alsynite NZ Limited**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Alsynite NZ Limited:**
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions.
 - d) Warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Alsynite NZ Limited**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Alsynite NZ Limited** or any third party.

For BRANZ



Chelydra Percy

Chief Executive

Date of Issue:

07 November 2014