

**E2SSA60****Staggered Steel Frame**

Non Load Bearing

Two Way FRR

**2** Layers: 1 Layer of Plasterboard on each side of frameFull Intertency **A**coustic

System Number	Lining Suffix	Fire Rating	Load Bearing Ability	Noise Control		Lining Requirement
				STC	Rw	
<b>E2SSA60</b>	<b>-F32</b>	--/60/60	NLB	55	54	1 x 16mm Elephant FireSmart on One side 1 x 16mm Elephant FireSmart to Other side

**Framing**

**Staggered Steel Frame** – Tracks to be a minimum size of 92mm x 30mm x 0.55 BMT and are fixed to floor and ceiling. Steel studs with minimum dimensions 64 x 34mm x 0.55 BMT with 6mm return.

Stud to be fixed to the tracks using Staggered Stud Clip and placed at 600mm centres with a 15mm expansion gap at top of frame.

Studs to be offset 300mm centres.

No other fixings to tracks are allowed.

**Wall Heights**

Recommended maximum height is 2.4m. Higher walls may be subject to specific engineering design or consult the framing manufacturer.

**Partition Width**

In order to achieve the STC ratings in the table above the partition width (excluding the board) shall be a minimum of 92mm.

Track Depth	Lining Suffix	Plasterboard	Total Partition
92mm	F32	32mm	124mm

**Wall Sound Absorber**

Install Sound Absorber between studs of the frame. Use 75mm thick R1.8 glass wool blanket. Split 600mm wide blankets into 300mm.

**Plasterboard Lining**

One layer of 16mm Elephant FireSmart lining fixed to each side of the Staggered steel framing.

Vertical fixing only permitted. Use full height sheets where possible. All sheet joints must be fixed over steel framing.

Sheet end butt joints must be formed over nogs. Sheets are fixed hard to the floor. Sheets shall be touch fitted.

**Fixing of Linings****Fasteners**

System Number	Side One	Side Two
	Single Layer	Single Layer
Self-Tapping Drywall Screws		
<b>E2SSA60-F32</b>	16mm	16mm
	32 x 6g	32 x 6g

**Fastener Centres**

Fix at 300mm centres up each stud with no fixing to top and bottom tracks.

Place fasteners no closer than 12mm to the sheet edge and 50mm from sheet ends.

Place fasteners at 200mm centres where sheet end butt joints occur.

**Acoustic Sealant**

A bead of acoustic sealant is required around the perimeter of the framing. The single layer is then bedded onto the bead. The perimeter junctions of the wall must be airtight.

**Jointing**

All fastener heads stopped and all sheet joints reinforced with paper jointing tape and stopped. Wall to ceiling junctions are to be reinforced with paper tape and square stopped or finished with Cornice. All in accordance with Elephant Plasterboard Installation Guide.

